SINGLE LINE



P_____ (PME -)

A#= 200KVA USED; 175KVA AVAIL
B#= 225KVA USED; 150KVA AVAIL
C#= 125KVA USED; 250KVA AVAIL

MELINDA 12KV/6.9KV
O'NEILL SUB

THIS PLAN APPROVED AS TO LOCATION AND TYPE OF ELECTRIC SUBSTRUCTURES

Developer: WILLIAM LYON HOMES
Attn: SCOTT MORROW / MORROW MANAGEMENT
Address: 1130 VIA CALLEJON
SAN CLEMENTE, CA 92673
Telephone: 949.218.8500
FAX:

Dwg./Rev.	Developer's Signature	Date
Original		
Rev.		
Rev.		
Rev.		

CHANGES IN THESE PLANS WILL REQUIRE AN ADDITIONAL 3 TO 4 WEEKS AND CUSTOMER WILL BE CHARGED IN ADVANCE FOR REQUESTED CHANGES.

D26| Rev. 02/12/08

LOAD INFORMATION

BLDG. SQ. FT. (ADJ. AVG.)	1800
LARGEST A/C UNIT (TONS)	3.5
AVG. A/C TONNAGE	3.5
DEMAND PER LOT (KW)	4
PANEL SIZE (AMP)	400A
CLIMATE ZONE	3
NUMBER OF UNITS	123
NUMBER OF ALLOWANCES	0
ALLOWANCES LOT NUMBERS	N/A

W/ 20% MULTI-FAMILY
RESIDENTIAL TRANSFORMER LOADING

25KVA	50KVA	75KVA
6	13	20

LINE EXTENSION
INSTALL METHOD:
☐ EDISON
☒ APPLICANT

PRELIMINARY
Not For Construction

UNDERGROUND SERVICE ALERT
Dial 811
Call USA
For Underground Locating
2 Working Days Before You Dig

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

SCALE: 1 IN = 40 FT
0 40 80

DATE	REVISION DESCRIPTION	APPROVED	DRAWN	CHECKED

DISTRICT: 43-SADDLEBACK	PROJ. MGR. PHONE		PLANNER PHONE		SR NO.
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. THOMAS GUIDE	GRID NO.	DESIGN NO.
CSD 140 Y ___ N ___ BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM ___ CHECKED ___	J.P.A. NO. ___ XLOAD		ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. TD - LINE EXTENSION		PRODUCT/SAP NO. TD - ST LT INSTALLATION			PRODUCT/SAP NO.
					PROPOSED CONSTRUCTION (LOCATION) PALOMA SQUARE DOVE CANYON DR. RANCHO SANTA MARGARITA
P	10/22/19		MORROW		
TYPE APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #	SHEET 1 OF 1
Southern California Edison Company					JOB NO. 0